



OFFICE OF THE DISTRICT MEDICAL AND HEALTH OFFICER,
MEDCHAL - MALKAJGIRI DISTRICT.


Rc.No. 098 / SHP / DM&HO / Medchal / 2026 - 27.

Dated: 15 / 05 / 2026.


SANITARY CERTIFICATE

I here by certified that Our Health Supervisor inspected the M/s Academic Heights Public School, Located at Plot No. 5/B, Nacharam X Roads, Nacharam, Uppal Mandal, Medchal-Malkajgiri District building and premises and certify that the accommodation provided for each of the several classes is sufficient for maximum number of pupils taught therein, and is properly ventilated and lighted, that the building is maintained in substantial repairs, is neat and clean, that the urinals & latrine arrangements are adequate and satisfactory and the supply of Safe drinking water is wholesome, and in all other necessary respects the Hygienic and sanitation is in good condition, for the Academic Year 2026 - 27.

This certificate should be got renewed by the starting of every academic year by applying to the District Medical & Health Officer, Medchal District.


District Medical & Health Officer,
Medchal - Malkajgiri District.


PRINCIPAL
ACADEMIC HEIGHTS PUBLIC SCHOOL
Plot No 5/B, Nacharam Cross Roads
MEDCHAL, MALKAJGIRI Dist-500076


MANAGER
ACADEMIC HEIGHTS PUBLIC SCHOOL
Plot No. 5/B, Nacharam,
Uppal Mandal, Medchal-Malkajgiri-500 076.



Vista Labs

Analytical • Biological • Environmental

An ISO 9001:2015 &
OHSAS ISO 45001:2018 Certified Lab



Regn. No.23DQLD43

TEST REPORT

Page 1 of 1

Name & Address Of Customer: M/s. Academic Heights Public School Plot NO-5/B, Near Nacharam-X-Roads, Nacharam, Uppal (M), Medchal-Malkajgiri Dist., Hyd, Telangana-500076.	Lab Ref. No:	VIS/904/2026
	Reporting Date:	19/05/2026
Sample Description: R.O.water	Sample Received On:	16/05/2026
	Your Ref No:	Verbal
Sample Condition At the time of Receipt: Found OK	Analysis Started On:	16/05/2026
Sample drawn By: Customer Quantity Received: 1Ltr X 1No.	Date of Sampling:	16/05/2026
	Analysis Completed On:	19/05/2026

TEST RESULTS

Sl. No.	Characteristic Physical & Chemical	Test method	Results	Requirement (Acceptable Limit) As per IS 10500:2012
1.	pH Value at 25°C	IS:3025(Part -11)-1983, RA 2017	6.82	6.50 - 8.50
2.	Electrical conductivity @ 25°C, µS/cm	APHA (23 rd Edn:2017) -2510 B	82	Not specified
3.	Total Dissolved solids, mg/l	IS:3025(Part -16)-1984, RA 2006	54	< 500
4.	Turbidity, (NTU)	IS:3025(Part -10)-1984, RA 2017	< 1.00	< 1.0
5.	Colour, (Hazen Units)	IS:3025(Part - 4)-1983, RA 2017	< 02	< 05
6.	Odour	IS:3025(Part - 5)-1983, RA 2018	Agreeable	Agreeable
7.	Total Hardness as CaCO ₃ , mg/l	IS:3025(Part -21)-2009, RA 2014	13	< 200
8.	Alkalinity to Phenolphthalein as CaCO ₃ , mg/l	IS:3025(Part -23)-1986, RA 2014	Nil	Not specified
9.	Alkalinity to methyl orange as CaCO ₃ , mg/l	IS:3025(Part -23)-1986, RA 2014	22	< 200
10.	Calcium as Ca, mg/l	IS:3025(Part -40)1991, RA 2014	3.2	< 75
11.	Magnesium as Mg, mg/l	APHA (23 rd Edn:2017)-3500-Mg B	< 2.0	< 30
12.	Sodium as Na, mg/l	IS:3025(Part -45)-1993, RA 2014	12.9	Not specified
13.	Potassium as K, mg/l	IS:3025(Part -45)-1993, RA 2014	< 1.0	Not specified
14.	Chloride as Cl, mg/l	IS:3025(Part -32)-1988, RA 2014	13.5	< 250
15.	Sulphate as SO ₄ , mg/l	IS:3025(Part -24)-1986, RA 2014	< 05	< 200
16.	Nitrate as NO ₃ , mg/l	IS:3025(Part -34)-1988, RA 2014	< 0.10	< 45
17.	Fluoride as F, mg/l	APHA (23 rd Edn:2017)-4500-F D	0.50	< 1.0
18.	Total Silica as SiO ₂ , mg/l	APHA (23 rd Edn:2017)- 4500 SiO ₂ C	< 1.00	Not specified
19.	Iron as Fe, mg/l	APHA (23 rd Edn:2017)- 3500 Fe B	0.050	< 0.3

MICROBIOLOGICAL

1.	Total coliform Bacteria, /100ml	IS: 15185:2002, RA2018	Absent	Shall be Absent
2.	Escherichia coli, /100ml	IS: 15185:2002, RA2018	Absent	Shall be Absent

IS 10500: 2012 = Drinking water Specification

Note:

1. This report is valid for the tested sample(s) only.
2. Test report shall not be reproduced except in full & with written approval of VISTALABS.
3. This report should not be used for advertisement / judicial purpose.
4. Total Number Of Test(S) TWENTY-ONE Only.
5. Lab will maintain unused portions of samples for 15 days after the report has been issued.

***** End of Report*****

 Checked By	 Authorized Signatory
----------------	--------------------------

VIS/LAB/F/047

4-9-6, Flat No. 103 & 104, Surya Towers, Adj. ANR Gardens, HMT Nagar, Nacharam, Hyderabad-500 076.
Ph : 040-27173815, 42210081, E-mail : vistalabs@yahoo.co.in, vistalabs2004@gmail.com

PRINCIPAL
ACADEMIC HEIGHTS PUBLIC SCHOOL
Plot No 5/B, Nacharam Cross Roads
MEDCHAL, MALKAJGIRI Dist-500076

MANAGER
ACADEMIC HEIGHTS PUBLIC SCHOOL
Plot No. 5/B, Nacharam,
Uppal Mandal, Medchal-Malkajgiri-500 076.